










Reaching Impact, Saturation and Epidemic Control (RISE)

PARTICIPANT HANDOUT- 3.1.1

Correct Answer

Gas
Carbon Dioxide
He-O₂
Instrument Air
Medical Air
Nitrogen
Nitrous Oxide
O₂-He
Oxygen
Vacuum (Suction)
WAGD (Evac)

ISO Color Code	
	Grey
	Brown and White
	Black and White
	Black
	Blue
	White and Brown
	White
	Yellow
	Purple

Disclaimer: This document was made possible with support from the United States Agency for International Development funded RISE program, under the terms of the cooperative agreement 7200AA19CA00003. The contents are the responsibility of the RISE program and do not necessarily reflect the views of USAID or the United States Government.



USAID
FROM THE AMERICAN PEOPLE

RISE
Reaching Impact, Saturation,
and Epidemic Control